



NOTES:

1. REFER TO MANUFACTURER'S CATALOG FOR CORRECT DIMENSIONS TO FIT SIZE OF SPECIFIED BACKFLOW.
2. COVER BACKFLOW ASSEMBLY WITH POLAR BLANKET TO PREVENT FREEZE DAMAGE.
3. DIMENSIONS OF CONCRETE PAD TO BE DETERMINED BY THE CITY ENGINEER FOR EACH INDIVIDUAL JOB.
4. AN APPROVED BACKFLOW PREVENTION ASSEMBLY SHALL BE INSTALLED ON EACH SERVICE LINE TO CUSTOMER'S WATER SYSTEM AT OR NEAR THE PROPERTY LINE AS PER TURLOCK MUNICIPAL CODE, SECTION 6-6.07.

STANDARD METER-BACKFLOW INSTALLATION

	DRAWN BY: JSH	CITY OF TURLOCK	DRAWING NO. W-12
	CHECK BY: NBB		APPROVED BY: 
	SCALE: NONE	CITY ENGINEER - MICHAEL G. PITCOCK - RCE 52694	